

Fort Monmouth Fire and Emergency Services
282 Saltzman AVE
Fort Monmouth, NJ 07703

Fort Monmouth Violation Notice


Thu Sep 4, 2003

Bowling Alley
689 Saltzman AVE
Fort Monmouth, NJ 07703


An inspection of your facility on Tue Jul 1, 2003 revealed the violations listed below.

ORDER TO COMPLY: Since these conditions are contrary to law, you must correct them upon receipt of this notice. An inspection to determine compliance with this Notice will be conducted on

Violation Code	Article	Division	Page
F-610.1 Egress illumination:			
Stairways, hallways and other means of egress, including exterior open spaces to or through which an exit leads, shall be kept adequately lighted at all times that the building served thereby is occupied.			



Flannigan, Craig
Inspector



Joe Himmelreich
Occupant/Owner

Fort Monmouth Fire and Emergency Services
282 Saltzman AVE
Fort Monmouth, NJ 07703

Fort Monmouth Violation Notice

Thu Sep 4, 2003

Community Center
552 Malterer AVE
Fort Monmouth, NJ 07703

An inspection of your facility on Tue Jul 22, 2003 revealed the violations listed below.

ORDER TO COMPLY: Since these conditions are contrary to law, you must correct them upon receipt of this notice. An inspection to determine compliance with this Notice will be conducted on Wed Oct 15, 2003


Violation Code	Article	Division	Page
----------------	---------	----------	------

F-309.2.1 Cleaning schedule:

Where a cleaning schedule is not on file, the fire official shall require a schedule to be submitted, indicating the method of cleaning and the time intervals between cleanings. Ovens and stoves require cleaning and maintenance.



Braumuller, Thomas
Inspector



Roberto Lara
Occupant/Owner

Fort Monmouth Fire and Emergency Services
282 Saltzman AVE
Fort Monmouth, NJ 07703

Fort Monmouth Violation Notice

Thu Sep 4, 2003

MWR Tickets N Tour Office
~~Carson Wagonlit Leisure Travel~~
1010 Alexander AVE
Fort Monmouth, NJ 07703

An inspection of your facility on Wed Aug 20, 2003 revealed the violations listed below.

ORDER TO COMPLY: Since these conditions are contrary to law, you must correct them upon receipt of this notice. An inspection to determine compliance with this Notice will be conducted on

Violation Code	Article	Division	Page
NFPA 1 Fire Prevention Code			
Fire extinguisher not mounted.			
Repaired 08/20/2003			



Braumuller, Thomas
Inspector

x 

Maritza Rivera
Occupant/Owner

Fort Monmouth Fire and Emergency Services
282 Saltzman AVE
Fort Monmouth, NJ 07703

Fort Monmouth No Violation Notice

Thu Sep 4, 2003

Fort Monmouth Marina
450 Riverside AVE
Fort Monmouth, NJ 07703

An inspection of your facility on Tue May 6, 2003 revealed no violations
to the Fire Code of Fort Monmouth.

Thank you for your cooperation.



Braumuller, Thomas /Fire Inspector
Inspector

Fort Monmouth Fire and Emergency Services
282 Saltzman AVE
Fort Monmouth, NJ 07703

Fort Monmouth Violation Notice

Thu Sep 4, 2003

Post Field House
114 Nicodemus AVE
Fort Monmouth, NJ 07703

An inspection of your facility on Wed Aug 27, 2003 revealed the violations listed below.

ORDER TO COMPLY: Since these conditions are contrary to law, you must correct them upon receipt of this notice. An inspection to determine compliance with this Notice will be conducted on Fri Nov 21, 2003

Violation Code	Article	Division	Page
05-01.9.2.1 General	05-01.9.2.1		
No furnishings, decorations, or other objects shall be placed to obstruct exits, access thereto, egress therefrom, or visibility thereof. Physical fitness equipment in egress corridor near hand ball courts.			
.....			
NFPA 1 Fire Prevention Code			
General Housekeeping in basement.			
.....			



Braumuller, Thomas
Inspector

x 

Sal Impollonia
Occupant/Owner